



P.O. Box 3097
 Battle Ground, WA. 98604

(360) 687-7668
 (360) 687-7669 FAX

Toil Free (877) 391-2850
 E-Mail calek@qwest.net

SITE AND SOIL EVALUATION

Property: Lot 1; NT Properties Subdivision, Sparrow Drive
 Legal: Portion of SW 1/4 of Section 8, Township 9 North, Range 1 West, WM
 Lot Size: 5.00 Acres
 Site Characteristics: Olympic Silt Loam, 8% NE slope in area of test holes

Soil Logs:

- TP 1 (SE) 0-16" Dk Br SiL; Med.-Fine Roots, 2FSBK
 16-60" Br SiL; 2MPR, No Restrictions
- TP 2 (N) 0-14" Dk Br SiL; Med.-Fine Roots, 2FSBK
 14-64" Br SiL; 2MPR, No Restrictions
- TP 3 (SW) 0-12" Dk Br SiL; Med.-Fine Roots, 2FSBK
 12-65" Br SiL; 2MPR, No Restrictions

Summary: Site meets requirements for Conventional (gravity) system at location of Test holes using 0.4 GPD/SF & restrictive layer of 60" (bottom of pit)

