



P.O. Box 3097
Battle Ground, WA. 98604

(360) 687-7668
(360) 687-7669 FAX

Toll Free (877) 391-2850
E-Mail calek@qwest.net

SITE AND SOIL EVALUATION

Property: Lot 2; N.T. Properties, LLC Subdivision, Silver Ridge Drive
 Legal: Portion of SW 1/4 of Section 8, Township 9 North, Range 1 West, WM
 Lot Size: 5.00 Acres
 Site Characteristics: Olympic Silt Loam, 12-15% NE slope in area of test holes
 Soil Logs:

- | | |
|------------------|--|
| <u>TP 1 (E)</u> | 0-11" Dk Br SiL; Med. Roots, 2FSBK |
| | 11-34" Br SiL; 2MSBK, No Restrictions |
| | 34"+ Br SiCL; 1MSBK, Moderate Mottles, Restrictive |
| <u>TP 2 (NW)</u> | 0-16" Dk Br SiL; Med. Roots, 2FSBK |
| | 16-60" Br SiL; 2MSBK, No Restrictions |
| <u>TP 3 (S)</u> | 0-18" Dk Br SiL; Med. Roots, 2FSBK |
| | 18-60" Br SiL; 2MSBK, No Restrictions |

Summary: Site meets requirements for Conventional (gravity) system at location of TP2 & TP3 using 0.4 GPD/SF & restrictive layer of 60" Reserve over TP1 requires shallow PD system using 0.4 GPD/SF & restrictive layer of 34".

