

P.O. Box 3097
 Battle Ground, WA. 98604

(360) 687-7668
 (360) 687-7669 FAX


Toll Free (877) 391-2850
 E-Mail calek@qwest.net

SITE AND SOIL EVALUATION

Property: Lot 6; Ffeonix, LLC Subdivision, Silver Ridge Drive
 Legal: Portion of SW 1/4 of Section 8, Township 9 North, Range 1 West, WM
 Lot Size: 5.00 Acres
 Site Characteristics: Olympic Silt Loam, 12% SE slope in area of test holes

Soil Logs:

- TP 1 (W)
 - 0-11" Dk Br SiL; Med. Roots, 2FSBK
 - 11-60" Br SiCL; 2MSBK, No Restrictions
- TP 2 (SE)
 - 0-11" Dk Br SiL; Med. Roots, 2FSBK
 - 11-50" Br GCL; 2MSBK, No Restrictions
 - 50"+ Br XGCL; >60% DPM (restrictive)
- TP 3 (NE)
 - 0-14" Dk Br SiL; Med. Roots, 2FSBK
 - 14-47" Br SiCL; 2MSBK, Flecks of DPM, No Restrictions
 - 47"+ Br XGCL; >60% DPM (restrictive)



2.11.08

Summary: Site meets requirements for Conventional (cap) system at location of Test holes using 0.4 GPD/SF & restrictive layer of 47 to 60".

