



P.O. Box 3097
 Battle Ground, WA. 98604

(360) 687-7668
 (360) 687-7669 FAX

Toll Free (877) 391-2850
 E-Mail calek@qwest.net

SITE AND SOIL EVALUATION

Property: Lot 5; Ffeonix, LLC Subdivision, Silver Ridge Drive
 Legal: Portion of SW 1/4 of Section 8, Township 9 North, Range 1 West, WM
 Lot Size: 5.00 Acres
 Site Characteristics: Olympic Silt Loam, 10% SE slope in area of test holes
 Soil Logs:

- | | |
|---------------------|---|
| <u>TP 1 (E)</u> | 0-15" Dk Br SiL; Med. Roots, 2FSBK |
| | 15-40" Br SiCL; 2MSBK, Flecks of DPM, No Restrictions |
| | 40"+ Br XGCL; >60% DPM (restrictive) |
| <u>TP 2 (N-mid)</u> | 0-17" Dk Br SiL; Med. Roots, 2FSBK |
| | 17-41" Br GCL; 2MSBK, No Restrictions |
| | 41"+ Br XGCL; >60% DPM (restrictive) |
| <u>TP 3 (W)</u> | 0-10" Dk Br SiL; Med. Roots, 2FSBK |
| | 10-38" Br SiCL; 2MSBK, Flecks of DPM, No Restrictions |
| | 38"+ Br XGCL; >60% DPM (restrictive) |

Summary: Site meets requirements for Pressure Distribution system at location of Test holes using 0.4 GPD/SF & restrictive layer of 38 to 41"

