

P.O. Box 3097
Battle Ground, WA. 98604


(360) 687-7668
(360) 687-7669 FAX

Toll Free (877) 391-2850
E-Mail calek@qwest.net

SITE AND SOIL EVALUATION

Property: Lot 4; Ffeonix, LLC Subdivision, Silver Ridge Drive
 Legal: Portion of SW 1/4 of Section 8, Township 9 North, Range 1 West, WM
 Lot Size: 5.00 Acres
 Site Characteristics: Olympic Silt Loam, 5% SE slope in area of test holes
 Soil Logs:

<u>TP 1 (E)</u>	0-16" Dk Br SiL; Med. Roots, 2FSBK
	16-52" Br SiL; 2MSBK, Flecks of DPM, No Restrictions
	52"+ Br VGCL; >30% DPM, 1MPR (restrictive)
<u>TP 2 (N)</u>	0-16" Dk Br SiL; Med. Roots, 2FSBK
	16-49" Br SiL; 2MSBK, Flecks of DPM, No Restrictions
	49"+ Br VGCL; >30% DPM, 1MPR (restrictive)
<u>TP 3 (NW)</u>	0-15" Dk Br SiL; Med. Roots, 2FSBK
	15-56" Br SiL; 2MSBK, No Restrictions



2.11.08

Summary: Site meets requirements for Conventional (gravity cap) system at location of Test holes using 0.4 GPD/SF & restrictive layer of 49 to 56"

