

P.O. Box 3097
Battle Ground, WA. 98604

(360) 687-7668
(360) 687-7669 FAX


Toll Free (877) 391-2850
E-Mail calek@qwest.net

SITE AND SOIL EVALUATION

Property: Lot 6; N.T. Properties, LLC Subdivision, Silver Ridge Drive
 Legal: Portion of SW 1/4 of Section 8, Township 9 North, Range 1 West, WM
 Lot Size: 5.00 Acres
 Site Characteristics: Olympic Silt Loam, 5% SW slope in area of test holes

Soil Logs:

<u>TP 1 (NE)</u>	0-14"	Dk Br SiL; Med. Roots, 2FSBK
	14-40"	Br SiL; 2MSBK, No Restrictions
	40-50"	Br GCL; ~20% DPM
	50"+	Br XGCL; 1MPR, >60% CF (restrictive)
<u>TP 2 (SE)</u>	0-10"	Dk Br SiL; Med. Roots, 2FSBK
	10-50"	Br SiL; 2MSBK, Flecks of DPM; No Restrictions
	50"+	Br XGCL; 1MPR, >60% CF (restrictive)
<u>TP 3 (SE)</u>	0-15"	Dk Br SiL; Med. Roots, 2FSBK
	15-48"	Br SiL; 2MSBK, No Restrictions
	48"+	Br XGCL; 1MPR, >60% CF (restrictive)



2.11.08

Summary: Site meets requirements for Conventional (gravity cap) system at location of test pits using 0.4 GPD/SF & restrictive layer of 48" to 50".

