

P.O. Box 3097
Battle Ground, WA. 98604

(360) 687-7668
(360) 687-7669 FAX

Toll Free (877) 391-2850
E-Mail calek@qwest.net


SITE AND SOIL EVALUATION

Property: Lot 4; N.T. Properties, LLC Subdivision, Silver Ridge Drive
Legal: Portion of SW 1/4 of Section 8, Township 9 North, Range 1 West, WM
Lot Size: 5.00 Acres

Site Characteristics: Olympic Silt Loam, 15% N-NE slope in area of test holes

Soil Logs:

<u>TP 1 (W)</u>	0-20" Dk Br SiL; Med. Roots, 2FSBK
	20-48" Br SiL; 2MSBK, No Restrictions
	48"+ Br SiCL; 1MPR, Moderate Mottles (restrictive)
<u>TP 2 (SW)</u>	0-13" Dk Br SiL; Med. Roots, 2FSBK
	13-60" Br SiL; 2MSBK, No Restrictions
<u>TP 3 (SE)</u>	0-14" Dk Br SiL; Med. Roots, 2FSBK
	14-60" Br SiL; 2MSBK, No Restrictions



Summary: Site meets requirements for Conventional (gravity) system over TP2 & TP3 using 0.4 GPD/SF & restrictive layer of 60". Reserve over TP1 requires shallow gravity cap system using 0.4 GPD/SF & restrictive layer of 48".

