

P.O. Box 3097
Battle Ground, WA. 98604

(360) 687-7668
(360) 687-7669 FAX


Toll Free (877) 391-2850
E-Mail calek@qwest.net

SITE AND SOIL EVALUATION

Property: Lot 5; N.T. Properties, LLC Subdivision, Silver Ridge Drive
 Legal: Portion of SW 1/4 of Section 8, Township 9 North, Range 1 West, WM
 Lot Size: 5.00 Acres
 Site Characteristics: Olympic Silt Loam, 20% E-SE slope in area of test holes

Soil Logs:

| | | |
|------------------|--------|--------------------------------------|
| <u>TP 1 (N)</u> | 0-9" | Dk Br SiL; Med. Roots, 2FSBK |
| | 9-55" | Br Cobbly SiL; 2MPR, No Restrictions |
| | 55"+ | Br XGCL; 1MPR, >60% CF (restrictive) |
| <u>TP 2 (SW)</u> | 0-11" | Dk Br Cobbly SiL; Med. Roots, 2FSBK |
| | 11-54" | Br Cobbly SiL; 2MPR, No Restrictions |
| | 54"+ | Br XGCL; 1MPR, >60% CF (restrictive) |
| <u>TP 3 (SE)</u> | 0-10" | Dk Br SiL; Med. Roots, 2FSBK |
| | 10-52" | Br SiL; 2MPR, No Restrictions |
| | 52"+ | Br XGCL; 1MPR, >60% CF (restrictive) |



Summary: Site meets requirements for Conventional (gravity) system at location of test pits using 0.4 GPD/SF & restrictive layer of 52" to 55".

