

P.O. Box 3097
Battle Ground, WA. 98604

(360) 687-7668
(360) 687-7669 FAX

Toll Free (877) 391-2850
E-Mail calek@qwest.net


SITE AND SOIL EVALUATION

Property: Lot 1; Ffeonix, LLC Subdivision, Elk Heights Drive
Legal: Portion of SW 1/4 of Section 8, Township 9 North, Range 1 West, WM
Lot Size: 5.00 Acres

Site Characteristics: Olympic Silt Loam, 8% E-NE slope in area of test holes

Soil Logs:

<u>TP 1 (NE)</u>	0-10"	Dk Br SiL; Med. Roots, 2FSBK
	10-47"	Br SiL; 2MSBK, No Restrictions
	47"+	Br GCL; 1MPR, Moderate Mottles, Restrictive
<u>TP 2 (NW)</u>	0-9"	Dk Br SiL; Med. Roots, 2FSBK
	9-44"	Br SiL; 2MSBK, No Restrictions
	44"+	Br GCL; 1MPR, Moderate Mottles, Restrictive
<u>TP 3 (S)</u>	0-9"	Dk Br SiL; Med. Roots, 2FSBK
	9-44"	Br SiL; 2MSBK, No Restrictions
	44"+	Br GCL; 1MPR, Moderate Mottles, Restrictive



Summary: Site meets requirements for Pressure Distribution (PD) system at location of test pits using 0.4 GPD/SF & restrictive layer of 44-47"

