

P.O. Box 3097  
Battle Ground, WA. 98604


(360) 687-7668  
(360) 687-7669 FAX

Toll Free (877) 391-2850  
E-Mail calek@qwest.net

### SITE AND SOIL EVALUATION

Property: Lot 2; Ffeonix, LLC Subdivision, Elk Heights Drive  
 Legal: Portion of SW 1/4 of Section 8, Township 9 North, Range 1 West, WM  
 Lot Size: 6.00 Acres  
 Site Characteristics: Olympic Silt Loam, 8% W-NW slope in area of test holes  
 Soil Logs:

<u>TP 1 (E)</u>	0-9"	Dk Br SiL; Med. Roots, 2FSBK
	9-52"	Br SiL; 2MSBK, No Restrictions
	52"+	Br GCL; 1MPR, Moderate Mottles, Restrictive
<u>TP 2 (N)</u>	0-10"	Dk Br SiL; Med. Roots, 2FSBK
	10-39"	Br SiL; 2MSBK, No Restrictions
	39"+	Br GCL; 1MPR, Moderate Mottles, Restrictive
<u>TP 3 (SW)</u>	0-7"	Dk Br SiL; Med. Roots, 2FSBK
	7-39"	Br SiL; 2MSBK, No Restrictions
	39"+	Br GCL; 1MPR, Moderate Mottles, Restrictive



EXPIRES: APRIL 28th 2008

2.11.08

Summary: Site meets requirements for Pressure Distribution (PD) system at location of test pits using 0.4 GPD/SF & restrictive layer of 39-52"

