

P.O. Box 3097  
Battle Ground, WA. 98604

(360) 687-7668  
(360) 687-7669 FAX

Toll Free (877) 391-2850  
E-Mail calek@qwest.net


### SITE AND SOIL EVALUATION

Property: Lot 4; Ffeonix, LLC Subdivision, Elk Heights Drive  
Legal: Portion of SW 1/4 of Section 8, Township 9 North, Range 1 West, WM  
Lot Size: 5.00 Acres

Site Characteristics: Olympic Silt Loam, 2% N-NE slope in area of test holes

Soil Logs:

<u>TP 1 (NE)</u>	0-11"	Dk Br SiL; Med. Roots, 2FSBK
	11-33"	Br SiL; 2MSBK, No Restrictions
	33"+	Br SiCL; 1MPR, Moderate Mottles, Restrictive
<u>TP 2 (Mid)</u>	0-9"	Dk Br SiL; Med. Roots, 2FSBK
	9-29"	Br SiL; 2MSBK, No Restrictions
	29"+	Br SiCL; 1MPR, Moderate Mottles, Restrictive
<u>TP 3 (SW)</u>	0-11"	Dk Br SiL; Med. Roots, 2FSBK
	11-26"	Br SiL; 2MSBK, No Restrictions
	26"+	Br SiCL; 1MPR, Moderate Mottles, Restrictive



Summary: Site meets requirements for Sand Filter (or equal) system at location of test pits using 0.4 GPD/SF & restrictive layer of 26-33"

