

P.O. Box 3097  
 Battle Ground, WA. 98604


(360) 687-7668  
 (360) 687-7669 FAX

Toll Free (877) 391-2850  
 E-Mail calek@qwest.net

SITE AND SOIL EVALUATION

Property: Lot 5; N.T. Properties Subdivision, Sparrow Drive  
 Legal: Portion of SW 1/4 of Section 8, Township 9 North, Range 1 West, WM  
 Lot Size: 5.00 Acres  
 Site Characteristics: Olympic Silt Loam, 11% West slope in area of test holes  
 Soil Logs:

- TP 1 (W) 0-16" Dk Br SiL; Med.-Fine Roots, 2FSBK  
 16-46" Br SiL; 2MPR, No Restrictions  
 46"+ Mixed Br XGCL; 1MPR, >60% DPM (restrictive)
- TP 2 (NE) 0-11" Dk Br SiL; Med.-Fine Roots, 2FSBK  
 11-55" Br SiL; 2MPR, No Restrictions  
 55"+ Mixed Br XGCL; 1MPR, >60% DPM (restrictive)
- TP 3 (S) 0-12" Dk Br SiL; Med.-Fine Roots, 2FSBK  
 12-55" Br SiL; 2MPR, No Restrictions  
 55"+ Mixed Br XGCL; 1MPR, >60% DPM (restrictive)



Summary: Site meets requirements for Conventional (gravity) system at location of TP2 & TP3 using 0.4 GPD/SF & restrictive layer of 55". Reserve over TP1 (West pit) requires Max. trench depth of 10" due to restr. at 46".

