



P.O. Box 3097
Battle Ground, WA. 98604

(360) 687-7668
(360) 687-7669 FAX

Toll Free (877) 391-2850
E-Mail calek@qwest.net

SITE AND SOIL EVALUATION

Property: Lot 1A; Ffeonix, LLC Site, Silver Ridge Drive
 Legal: Portion of SW 1/4 of Section 8, Township 9 North, Range 1 West, WM
 Lot Size: 5.00 Acres
 Site Characteristics: Olympic Silt Loam, 12-20% NW slope in area of test holes
 Soil Logs:

<u>TP 1 (W)</u>	0-20" Dk Br SiL; Med. Roots, 2FSBK
	20-44" Br SiL; 2MSBK, No Restrictions
	44"+ Br XGCL; >60% CF, Restrictive
<u>TP 2 (N)</u>	0-16" Dk Br SiL; Med. Roots, 2FSBK
	16-48" Br SiL; 2MSBK, No Restrictions
	48"+ Br XGCL; >60% DPM (restrictive)
<u>TP 3 (NE)</u>	0-16" Dk Br SiL; Med. Roots, 2FSBK
	16-36" Br SiL; 2MSBK, No Restrictions
	36"+ Br XGCL; >60% DPM (restrictive)

Summary: Site meets requirements for Pressure Distribution (PD) system at location of Test holes using 0.4 GPD/SF & restrictive layer of 36-48".

