

P.O. Box 3097
Battle Ground, WA. 98604


(360) 687-7668
(360) 687-7669 FAX

Toll Free (877) 391-2850
E-Mail calek@qwest.net

SITE AND SOIL EVALUATION

Property: Lot 1; N.T. Properties, LLC Subdivision, Silver Ridge Drive
 Legal: Portion of SW 1/4 of Section 8, Township 9 North, Range 1 West, WM
 Lot Size: 10.00 Acres
 Site Characteristics: Olympic Silt Loam, 15-16% N-NW slope in area of test holes
 Soil Logs:

- TP 1 (E)
 - 0-19" Dk Br SiL; Med. Roots, 2FSBK
 - 19-45" Br SiCL; Flecks of DPM; 2MSBK, No Restrictions
 - 45"+ Br XGCL; >60% CF, Restrictive
- TP 2 (S)
 - 0-16" Dk Br SiL; Med. Roots, 2FSBK
 - 16-42" Br GCL; 2MSBK, No Restrictions
 - 42"+ Br XGCL; >60% DPM (restrictive)
- TP 3 (NW)
 - 0-14" Dk Br SiL; Med. Roots, 2FSBK
 - 14-60" Br SiL; 2MSBK, No Restrictions



Summary: Site meets requirements for Pressure Distribution (PD) system at location of Test holes using 0.4 GPD/SF & restrictive layer of 42 to 60".

