

P.O. Box 3097
Battle Ground, WA. 98604


(360) 687-7668
(360) 687-7669 FAX

Toll Free (877) 391-2850
E-Mail calek@qwest.net

SITE AND SOIL EVALUATION

Property: Lot 1A; N.T. Properties, LLC Site, Silver Ridge Drive
 Legal: Portion of SW 1/4 of Section 8, Township 9 North, Range 1 West, WM
 Lot Size: 5.00 Acres
 Site Characteristics: Olympic Silt Loam, 12% E-SE slope in area of test holes
 Soil Logs:

<u>TP 1 (SE)</u>	0-14"	Dk Br SiL; Med. Roots, 2FSBK
	14-39"	Br SiL; 2MSBK, No Restrictions
	39"+	Br VGCL; 1MPR, Moderate Mottles (restrictive)
<u>TP 2 (N)</u>	0-20"	Dk Br SiL; Med. Roots, 2FSBK
	20-44"	Br GSiL; 2MSBK, No Restrictions
	44"+	Br XGCL; 1MPR, Moderate Mottles (restrictive)
<u>TP 3 (SW)</u>	0-10"	Dk Br SiL; Med. Roots, 2FSBK
	10-45"	Br SiL; 2MSBK, No Restrictions
	45"+	Br XGCL; 1MPR, Moderate Mottles (restrictive)



Summary: Site meets requirements for Pressure Distribution (PD) system at location of test pits using 0.4 GPD/SF & restrictive layer of 39" to 45".

